



Fael Security Srl
Via E. Majorana
72100 Brindisi - ITALIA
Tel. 0831-546563
E-mail: fael@fael.com
Web: faelsecurity.com

**EI₂ 120 TELESCOPIC SLIDING DOOR
"CROSSWALK 120 T"**

Marked CE according to EN 16034:2014 and 13241:2016


- Telescopic fire door only for internal use.
- Install in a location that is not subject to high winds.
- Installation only by specialists.
- Install on levelled and coplanar compartments.

Client: _____

ORDER.N°: _____ dd _____


ST1 (Sheet Mod. 850-A)

Telescopic Sliding Door Q.ty: _____




LVM. _____ × HVM. _____
Opening direction pull left

Telescopic Sliding Door Q.ty: _____




LVM. _____ × HVM. _____
Opening direction pull right

Telescopic Sliding Door (Rebated) Q.ty: _____




LVM. _____ × HVM. _____
Opening direction pull left

Telescopic Sliding Door (Rebated) Q.ty: _____



LVM. _____ × HVM. _____
Opening direction pull right




Doors elements made of independent panels
Planned deformability panels

LVM = Structural Opening Width
HVM = Structural Opening Height
FFL = Finished Floor Level

Standard Assembly

Vertical Section

Standardised Rigid Support (EN 1363-1)




Standard

Mounting on Beam

Vertical Section

Standardised Flexible Support (EN 1363-1)



On Beam

ACCESSORIES

MANDATORY

- Electromagnet + release button
- Radial Damper
- Shock Absorber

OPTIONALS

- Rebated (counterweight reverted)
- Detector (smoke and heat) RFC
- RFC/C single zone fire alarm

RAL: _____

Note:

Note: Anchoring screws for the structure are **NOT** included.

DATE: _____

Stamp and Signature: _____